


**SUMMARY OF RESULTS  
OF TESTING CERTIFICATE 09124 / 10.11.2009**

|               |              |             |                       |
|---------------|--------------|-------------|-----------------------|
| <b>NUMBER</b> | <b>09124</b> | <b>DATE</b> | <b>10 / 11 / 2009</b> |
|---------------|--------------|-------------|-----------------------|

|                             |   |
|-----------------------------|---|
| <b>Client' s data:</b>      | <b>ETEM S.A.<br/>LIGHT METALS COMPANY<br/>1, IROON POLYTEHNIU STR.<br/>GR 196 00 MAGOULA ATTIKIS - GREECE</b> |
| <b>Product description:</b> | <b>SINGLE SASH BALCONY DOOR<br/>TILT / TURN</b>   |
| <b>Material:</b>            | <b>ALUMINIUM</b>  |
| <b>System :</b>             | <b>E - 1000</b>   |



|  |                 |
|--|-----------------|
| <b>Air Permeability</b><br><i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>         | <b>Class 4</b>  |
| <b>Watertightness</b><br><i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>           | <b>Class 9A</b> |
| <b>Resistance to Wind Load</b><br><i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i> | <b>Class C3</b> |

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPADOPOULOU  
TECHNICAL MANAGER**



**IOANNIS GKERTSOS  
GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL